



## **Pinnacle Heavy Duty Cabinet**

### **MATERIALS:**

**SHEET STEEL:** All parts made from prime grade mild cold rolled sheet steel free from surface imperfection, and capable of taking a high grade enamel finish.

**HINGES:** .074" thick, 2" high, double spun, full loop, tight pin, five-knuckle hinges, projection welded to door frame and securely fastened to the door with 2 steel rivets. Doors over 42" high shall have three hinges; all other doors shall have two hinges.

**FINISHING:** Chemically pretreated metal with a six stage cleaning phosphatizing and metal preparation process. Finish coat shall be baked on powder coated enamel. Select colors from manufacturer's minimum standard 31 colors. All lockers shall be painted inside and outside with the same color.

**EQUIPMENT:** Coat hooks and coat rods are zinc plated. Truss fin head bolts and hex nuts are zinc coated.

**FABRICATION GENERAL CONSTRUCTION:** Built on the unit principle - each locker shall have an individual door and frame, individual top, bottom, back and shelves with common intermediate uprights separating compartments. Lockers shall be fabricated square, rigid and without warp. Doors shall be flat and free of distortion.

**DOOR FRAME:** All door frame members to be not less than 14 gauge formed to a channel shape. Vertical members to have an additional flange to provide a continuous door strike. Intermembering parts to be mortised and tenoned and electrically welded together in a rigid assembly capable of resisting strains. Cross frame members of 16 gauge channel shapes including intermediate cross frame on double and triple tier lockers shall be securely welded to vertical framing members to ensure rigidity.

**BODY:** Bolt spacing in locker body construction not to exceed 9" o.c. All locker body components shall be made of cold rolled steel specially formed for added strength and rigidity and to ensure tight joints at fastening points. Tops & bottoms shall be 16 gauge with three sides formed 90 degrees and the front offset formed to be flush with the horizontal frame member. Shelves and sides shall be 16 gauge with four sides formed to 90 degrees, the front edge shall have a second bend. Backs shall be 18 gauge.

**DOORS:** Doors 30" or higher shall be formed from one piece 14 gauge cold rolled sheet steel. Formations shall consist of a full channel shape on the lock side of adequate depth to fully conceal the lock bar, channel formation on the hinge side, and right angle formations across the top and bottom. Doors over 15" wide x 60" or 72" high shall have a 3" wide 20 gauge full height reinforcing pan welded to the inside face of the door on 6" centers. ~ 14 gauge as standard without front ventilation or upon request or requirement.

**DOOR HANDLE & LATCHING:** Provide handles recessed in the door with finger lift control. 20 gauge drawn pocket shall be brushed stainless steel securely fastened to the door with two tabs plus a positive tamper resistant decorative fastener. The pocket shall be of sufficient depth to prevent a combination padlock, built-in combination lock or key lock from protruding beyond the face of the door. A lock hole cover plate shall be provided for use with padlocks. The lifting piece shall be 14 gauge formed steel, attached to the latching channel with one concealed retaining lug and one rivet assuring a positive two point connection. Handle finger lift shall have a padlock eye for use with a 9/32" diameter padlock shackle. It shall have a sound deadening molded comfortable finger lift attached. Doors to have latch clip engaging the door frame at three points on doors over 42" high and two points on all other doors. Locking device to be positive, automatic type, whereby locker door may be locked when open, then closed without unlocking. One rubber silencer shall be firmly secured in the frame at each heavy gauge latch hook. Latch clips shall be glass filled nylon for long life and low friction and shall hold doors shut by engaging the latch hooks. The latch channel assembly shall be quieted by the use of unique nylon glides to reduce noise.~  
Note; Single point latching available with no latch channel or moving parts in the door.

**BODY:** Cabinet shall be assembled using rivets or bolts as specified.

**WE RESERVE THE RIGHT TO VARY SPECIFICATIONS CONSISTENT WITH ITS  
POLICY OF CONTINUOUS PRODUCT IMPROVEMENT.**